

ADDENDUM NO. 4

to the Contract Documents
for the Construction of the

SRAA OFFICE EXPANSION

at

SYRACUSE HANCOCK INTERNATIONAL AIRPORT
SYRACUSE REGIONAL AIRPORT AUTHORITY
SYRACUSE, NEW YORK

IFB REFERENCE #2021-08

TO ALL HOLDERS OF CONTRACT DOCUMENTS:

Your attention is directed to the following interpretations of changes in and additions to the Contract Documents for the construction of the **SRAA OFFICE EXPANSION** project at the Syracuse Hancock International Airport, Syracuse, New York. This Addendum is part of the Contract Documents in accordance with the provisions of Section 20-15, Addenda and Interpretation.

GENERAL:

1. Refer to attached document for summary of responses to inquiries received.
2. There has been no change to the bid opening date and time – it is per Addendum #1 at 1:30 PM on December 10, 2021.

CORRECTIONS TO PREVIOUS ADDENDA:

3. In Addendum #3, Item 3: **DELETE “10:00 am, local time, on December 10, 2021,”** and **SUBSTITUTE THEREFORE “1:30 pm, local time, on December 10, 2021,”**

END OF ADDENDUM NO. 4

C&S ENGINEERS, INC.



Michael W. LaMontagne, AIA
Principal Architect

SRAA Office Expansion
Response to Inquiries - Addendum #4



IFB Reference 2021-08

Question		Response
1.	<p>Request for Clarification:</p> <p><i>Is there more info on whether or not Seismic requirements are needed? We need to Know what category the building is in. (A,B,C etc.)</i></p>	<p>There are no seismic requirements for this project. Design Category is B.</p>