



ADDENDUM #03

September 21, 2023

RFI #1:

Can you please advise if traditional Non-Arc Resistant Switchgear will be considered based on lead time and cost impact to the project?

Response:

Arc Resistant Switchgear is required. Ideally, the full switchgear lineup including the switches should be Arc Resistant. If this is not feasible in the manufacturers design, please identify what components/compartments will not be Arc Resistant as a deviation. Proper labeling would be required identifying which components/compartments are not Arc Resistant if the proposal/deviation are accepted.

